



NOTE:
PROVIDE ELECTRIC SUPPLY AND
CAT 6 SUPPLY TO
SIX CUBICLES IN THIS ROOM.

EXISTING LAYIN
FLUORESCENT FIXTURE
TYPICAL

EXIST. SPRINKLER HEAD (TYP.)

RELOCATE 2 EXIST. EGG
CRATE AND DUCT TO
OTHER SIDE OF ROOM

APPROXIMATE
LOCATION OF
MAIN EXISTING
DUCT

NEW 2" X 4" WOOD STUD WALL, FULL
HEIGHT. W/ 1/2" GYPSUM BOARD TO
ABOVE EXIST. SUSPENDED ACOUSTIC
TILE CEILING. ADJUST EXIST. SUSP. ACT.
TILE ALONG BOTH SIDES OF NEW WALLS.

NEW 24" X 24" RETURN AIR GRILL UP TO
NEW 16" X 8" R.A. DUCT (790 CFM).

RELOCATE EXIST. SUPPLY AIR DIFFUSER
(240 CFM) TO THIS LOCATION
ADJUST 8" INSUL. FLEXIBLE DUCT.

EXISTING
SOUND
SYSTEM

RELOCATE EXISTING
2' X 4' LAYIN LIGHT
FIXTURE (WIRE IN
CONDUIT)

EXIST. SPRINKLER HEAD (TYP.)

EXIST. 1/4" DIA. SPRINKLER LINE

NEW DUPLEX EACH SIDE OF WALL AS SHOWN (8)
NEW CAT 6 BOX EACH SIDE OF WALL
ALL ELECTRIC IN CONDUIT.

REUSE OWNER SUPPLIED:
3'-0" X 6'-8" X 1 3/4" WOOD
DOOR AND FRAME.
MATCH EXIST. WOOD TRIM.
PROXIMITY READER HARDWARE
(MATCH EXIST.) LEVER
HANDLES, EXIT HARDWARE
BRIGHT BRASS FINISH

NEW EXIT LIGHT (NEL)
CONNECT TO EXISTING
EXIT LIGHT CIRCUIT
IN CONDUIT TYPICAL
2 PLACES

CONNECT TO EXIST. 1/4" DIA.
SPRINKLER LINE AND INSTALL
5 NEW SPRINKLER HEADS (NSH) TO
MATCH EXISTING. CONFORM TO NFPA 13

REUSE OWNER SUPPLIED:
3'-0" X 6'-8" X 1 3/4" WOOD
DOOR AND FRAME.
MATCH EXIST. WOOD TRIM.
PROXIMITY READER HARDWARE
(MATCH EXIST.) LEVER
HANDLES, OFFICE HARDWARE
BRIGHT BRASS FIN.

NOTE: ALL QUAD RECEPTACLES
TO BE WIRED IN METAL CONDUIT
COMPLETE.

NOTE: PROVIDE LOW VOLTAGE AND
CAT 6 CAPABILITY TO THE TWO NEW DOOR
LOCATIONS FOR PROXIMITY READERS USE.

NOTE: ALL CAT 6 BOXES TO
HAVE CONDUIT RUN IN WALL
TO ABOVE CEILING.

EXIST. SPRINKLER HEAD (TYP.)

EXISTING LAYIN
FLUORESCENT FIXTURE
TYPICAL

APPROXIMATE LOCATION
OF MAIN EXISTING DUCT

CONNECT TO NEW
12" X 24" DUCT

TRANSITION EX. 24" X 24"
TO A 10" X 12" DUCT W/
A MANUAL VOLUME DAMPER

NEW MANUAL
VOLUME DAMPER

720 CFM

EXIST. SUSP.
HVAC UNIT

EXIST. TRANSITION DUCT
CONVERT TO A 12" X 24" DUCT

MOVE EXIST. EGG
CRATE RETURN AIR

EX. OUTSIDE AIR
SUPPLY DUCT.

GENERAL NOTES:

ALL WORKMANSHIP AND MATERIALS SHALL BE IN CONFORMANCE TO THE
REQUIREMENTS OF THE DIVISION OF INDUSTRY SERVICES OF THE DEPARTMENT
OF SAFETY AND PROFESSIONAL SERVICES OF THE STATE OF WISCONSIN AND
APPLICABLE LOCAL CODES.

SPRAY TEXTURE WALLS TO MATCH EXISTING FINISH. PAINT SELECTED BY OWNER.

REPLACE MISSING OR DAMAGED CEILING TILES TO MATCH EXISTING TILE.

REBALANCE THE AFFECTED FURNACE SYSTEM.

ALL LUMBER FOR STUDS AND PLATES SHALL BE SPRUCE PINE FIR STUD GRADE
fb = 600 PSI, fc = 625 PSI, E = 1,200,000 PSI

WISCONSIN ADMINISTRATIVE CODE TYPE EXIT LIGHT. IN THE EVENT OF POWER FAILURE, AN
EMERGENCY SYSTEM SHALL AUTOMATICALLY ILLUMINATE THE PORTION OF THE EXTERIOR EXIT
DISCHARGE IMMEDIATELY ADJACENT TO EXIT DISCHARGE DOORWAYS IN BUILDINGS REQUIRED
TO HAVE TWO OR MORE EXITS. THE EMERGENCY POWER SYSTEM SHALL PROVIDE POWER FOR
A DURATION OF NOT LESS THAN 90 MINUTES AND SHALL CONSIST OF STORAGE BATTERIES,
UNIT EQUIPMENT OR AN ON-SITE GENERATOR. EMERGENCY POWER IS REQUIRED ON THE
OUTSIDE OF THE BUILDING TO ILLUMINATE THE EXITS. (IBC 1003.2.11.2)

ALL LUMBER FOR PLATES TO BE TREATED.

PARTIAL REVISION PLAN

SCALE: 1/4" = 1'-0"

NORTH

OWNER: RICHLAND COUNTY HHS
221 WEST SEMINARY STREET
RICHLAND CENTER, WI 53581

PROJECT: RICHLAND COUNTY HEALTH
AND HUMAN SERVICES
221 WEST SEMINARY STREET
RICHLAND CENTER, WI 53581

PROPOSED WALL PARTITION PROJECT

PROPOSED REVISION PLAN AND NOTES

WOODLAND CONSULTANTS, INC.

ENGINEERING AND BUILDING DESIGN
P.O. BOX 548 - 755 VALLEY VIEW DRIVE
RICHLAND CENTER, WISCONSIN 53581
www.woodlandconsultants - woodland@mwt.net
PHONE (608) 647-2191 FAX (608) 647-2192

DATE: MARCH 16, 2015

DRAWN BY: WAS

CHECKED BY: LDF

REVISION DATES:

77.063

JOB NO.

1 OF 1

SHEET NO.